

Job Information Technical Data Sheet

Job Name Unit Tag SFL Parts WSHP Partners Program

2.0 Ton LH



Unit Overview										
Model Number	Voltage V/Hz/Phase	Airflow CFM	Fluid Flow gpm	Cooling Capacity Btu/hr	Cooling Efficiency EER @ AHRI	Heating Capacity Btu/hr	Heating Efficiency COP @ AHRI			
WGCV024	208-230/60/1	836	6.00	22006	13.5	26549	4.5			

Unit			
Model Number:	WGCV024		
Unit Type:	Compact Vertical Single Stage		
Approval:	ETL, CETL, AHRI		
Configuration	Refrigerant Type	Refrigerant Weight	Loop Temperature Range
Vertical	R-410A	32 O oz	Water Loop (Standard Range)

Unit Perform	nance										
				A	ir & Water Flo	w					
Airflow Total E		Total Ext	External Static Pressure Fluid		Fluid Flow	Flow Fluid Type			Į.	Altitude	
836 сғм			0.30 inH₂O	o 6.00 gpm / 3.00 gp		om/ton	Water		0 ft		
Cooling Performance											
Fluid Tempe	erature		Air Temp	erature			Capacity	Heat of	EER @	Fluid	
Entering	Leaving	En	tering	Leav	/ing	Total	Sensible	Rejection	AHRI		
°F	°F	Dry Bulb °F	Wet Bulb °F	Dry Bulb °F	Wet Bulb °F	Btu/h	r Btu/hr	Btu/hr		Drop ft H₂O	
90.0	99.6	75.0	63.0	56.4	53.8	2200	6 16826	28829	13.5	12.13	
	Heating Performance										
Fluid 1	Temperature		Air Ten	perature	(Capacity	Heat of	COP @) AHRI	Fluid Pressure	
Entering	g Leaving		Entering	Leaving	g	Total	Absorption			Drop	
°F	0	F	Dry Bulb °F	Dry Bul °F	b	Btu/hr	Btu/hr			ft H₂O	
70.0	63	3.0	70.0	99.2		26549	21131	4	.5	12.56	

^{*}System WPD is calculated without the autoflow valve as the CV of an autoflow valve varies dependent on the system WPD. As long as the WPD is >3 psid, the autoflow valve will provide the selected GPM flowrate.

Electrical			
Unit Voltage	Minimum Voltage	Total Unit Full Load Current	Total Unit MCA
208-230/60/1	197.0 v	16.40 A	19.77 A
Compressor RLA	Compressor LRA	Motor FLA	Maximum Recommended Fuse Size / HACR Breaker Size
13.5 A	58.3 A	2.90 A	30 A

Physical								
Unit								
Depth	Height	Width	We	Weight		Connection		
			Shipping	Operating	Water	Condensate		
21.50 in 39.00 in 21.50 in		197 lb	169 lb	0.75 in	0.75 in			
Fan								
	Motor Type			Motor Horsepower				
ECM Constant Torque				0.33 hp				

Discharge Air Location:



Unit Options Controls Unit Control: Microtech III Control Transformer: Standard 50 VA Transformer Thermostat / Sensor Control: Thermostat Control Unit Airflow Configuration Return Air Location: Left Hand

Factory Mounted Options

Coaxial Heat Exchanger Options

Heat Exchanger: Copper Inner Tube / Steel Outer Tube

Top

Construction Options Drain Pan Material Primary: Stainless Steel **Filters** Filter Rack Type: 1-inch Rail Filter Type: Standard 1 inch (Quantity) Filter Dimensions: (1) 20 in x 20 in x 1 in Insulation Compressor Compartment: 1/2 inch Fiberglass, Skin-faced Air Compartment: 1/2 inch Fiberglass, Skin-faced

Warranty


Unit Warranty: 1st Year Labor Allowance


AHRI Certification





All equipment is rated and certified in accordance with AHRI / ISO 13256-1 and tested, investigated, and determined to comply with the requirements of the standards for Heating and Cooling Equipment UL-1995 for the United States and CAN/CSA-C22.2 NO.236 for Canada.

3/4 VIEW - LEFT HAND RETURN UNIT









NOTES						
[A] - High Volt Pwr Entry 1.1 DIA	[B] - Low Volt Pwr Entry 0.8 DIA	[C] - Condensate Drain 3/4" FPT				
[D] - Supply Water 3/4" FPT	[E] - Return Water 3/4" FPT	[F] - Unit Front Service Clearance 24				

Product: Project Name: SFL Parts WSHP Partners Program 13600 Industrial Park Blvd. Minneapolis, MN 55-	Product Drawing	Unit Tag: 2.0 Ton LH			DAIKIN		
Mandal, MCCVOOA	Product:	Project Name:	: SFL Parts WSHF	P Partners Progra	am		
	Model: WGCV024	Sales Office: Daikin Applied South Florida					
Sales Engineer: Dec. 10, 2018 Ver/Rev: Sheet 1 of 1 Scale: NTS Tolerance: +/-0.25" Dwg Units: (in	Sales Engineer:	Dec. 10, 2018	Ver/Rev:	Sheet 1 of 1	Scale: NTS	Tolerance: +/-0.25"	Dwg Units: (in)

No change to this drawing may be made unless approved in writing by Daikin Applied. Purchaser must determine that the equipment is fit and sufficient for the job specifications.